

Application News

High Performance Liquid Chromatography

Analysis of 1, 2, 3-Benzotriazole in Electrical Insulating Oil with Prominence-i

No.L511

Electrical insulating oils are used widely in oil-immersed transformers and oil-filled capacitors. When abnormal heating or insulation degradation occurs inside oil-filled equipment, gas produced by decomposition of the insulating oil and products of insulator deterioration will mix with the insulating oil and change its chemical properties. Quantitation of 1, 2, 3-benzotriazole is used as a method for testing the performance of insulating oil. 1, 2, 3-benzotriazole is often added to electrical insulating oil to suppress streaming electrification during cooling, and prevent sulfidation corrosion. It is also known to improve thermal stability and electrical properties. The method used to quantify 1, 2, 3-benzotriazole in electrical insulating oils is described in JIS C 2101 "Testing methods of electrical insulating oils."

An example analysis of 1, 2, 3-benzotriazole in electrical insulating oil is described here using the new Prominence-i integrated high performance liquid chromatograph.

Standard Solution Analysis

Fig. 1 shows the structural formula of 1, 2, 3-benzotriazole.

A standard solution was pretreated based on JIS C 2101, and analyzed with the Prominence-i integrated high performance liquid chromatograph. The analytical conditions used are shown in Table 1. JIS C 2101 states to pretreat a standard solution by obtaining 1 kg of electrical insulating oil containing no 1, 2, 3-benzotriazole (mentioned in JIS C 2320 "Electrical insulating oils") then adding 1, 2, 3-benzotriazole. For the purpose of this experiment, our sample was prepared by obtaining 1/10 the amount of electrical insulating oil (100 g), adding 10 mg of 1, 2, 3-benzotriazole, then performing the pretreatment process shown in Fig. 2. The standard reference solution containing the equivalent of 100 mg/kg 1, 2, 3-benzotriazole, which was obtained by this method was then diluted with a water-ethanol (6:4 [v/v]) mixture, and used for analysis.

Fig. 3 shows the chromatogram obtained for the 10 mg/kg 1, 2, 3-benzotriazole standard solution.

JIS C 2101 mentions using an injection volume of 50 μ L. However, an injection volume of 5 μ L was used in this study due to a possible negative effect on peak shape.




Fig. 1 Structural Formula of 1, 2, 3-Benzotriazole




Fig. 2 Pretreatment of Standard 1, 2, 3-Benzotriazole Solution in Insulating Oil




Fig. 3 Chromatogram of Standard Solution (10 mg/kg, 5 μL injection)

Table 1 Analytical Conditions

Column : Shim-pack VP-ODS (150 mm L. × 4.6 mm I.D., 5 μm)

Mobile Phase : Water/Methanol = 6/4 (v/v)

 $\begin{tabular}{lll} Flowrate & : 1.0 mL/min \\ Column Temp. & : 40 °C \\ Injection Volume & : 5 <math>\mu L \\ Detection & : UV 270 nm \\ \end{tabular}$

■ Calibration Curve Linearity

1, 2, 3-benzotriazole standard solutions were prepared in the range of 0.1 to 20 mg/kg and analyzed. The resulting calibration curve is shown in Fig. 4, and shows that good linearity was obtained.

Fig. 5 shows the chromatogram obtained for 0.1 mg/kg 1, 2, 3-benzotriazole standard solution.




Fig. 4 Calibration Curve Linearity




Fig. 5 Chromatogram of Standard Solution (0.1 mg/kg, 5 µL injection)

Analysis of 1,2,3-Benzotriazole in Electrical Insulating Oil

Two types of electrical insulating oil were pretreated as shown in Fig. 6. The oils were analyzed after methanol extraction without dilution.

The results of analysis are shown in Fig. 7 and Fig. 8. Electrical insulation oil A contained the equivalent of 0.5 mg/kg 1, 2, 3-benzotriazole, and electrical insulation oil B contained the equivalent of 8.0 mg/kg 1, 2, 3-benzotriazole.




Fig. 6 Sample Oil Pretreatment




Fig. 7 Electrical Insulating Oil A Chromatogram




Fig. 8 Electrical Insulating Oil B Chromatogram

First Edition: Oct. 2016



Shimadzu Corporation www.shimadzu.com/an/

For Research Use Only. Not for use in diagnostic procedure.

This publication may contain references to products that are not available in your country. Please contact us to check the availability of these products in your country.

The content of this publication shall not be reproduced, altered or sold for any commercial purpose without the written approval of Shimadzu. Company names, product/service names and logos used in this publication are trademarks and trade names of Shimadzu Corporation or its affiliates, whether or not they are used with trademark symbol "TM" or "®". Third-party trademarks and trade names may be used in this publication to refer to either the entities or their products/services. Shimadzu disclaims any proprietary interest in trademarks and trade names other than its own.

The information contained herein is provided to you "as is" without warranty of any kind including without limitation warranties as to its accuracy or completeness. Shimadzu does not assume any responsibility or liability for any damage, whether direct or indirect, relating to the use of this publication. This publication is based upon the information available to Shimadzu on or before the date of publication, and subject to change without notice.